

COMMUNITY COLLEGE OF ALLEGHENY COUNTY
PURCHASING DEPARTMENT
800 ALLEGHENY AVENUE, PITTSBURGH, PA 15233

ADDENDUM 1
BID PROPOSAL NO. 1138-2
EGRESS LIGHTING MODIFICATIONS – BOYCE CAMPUS
JULY 30, 2025

The following additional information is hereby made a part of this bid:

1. The due date has been extended two weeks to Wednesday, August 20, 2025 at 2:00 p.m.
2. Project schedule - Substantial completion by April 30, 2026
3. Building will be staffed from 6:00AM, Monday through Friday, non-holidays.
4. Contractors will check in with security - a contractor key may be made available.
5. Contractor will be provided with an inside storage room - need for contractor trailer is not expected.
6. Contractor provide systems testing - allow 16 hours Saturday (two Saturdays) shift - staffing as described in document set - (testing as described in the document set).
7. The Enlighted programming of existing Enlighted switches is removed form the project.
8. MC cable is acceptable in concealed locations - must be supported per the NEC - do not support from ductwork or other systems.
9. Contractor shall provide UL 924 shunt style relays as described in document set for each/ all lighting fixtures on egress circuits (except auditorium and gym).
10. The electrical contractor shall serve as the prime contractor. This contractor shall provide any and all (general contractor) services required such as floor protection; patching; painting; fire stopping; permitting and other general contractor services - provide the services of a sub contractor as necessary.
11. Please see all drawing and specification sections, and section 260500, 1.4 for additional permitting information.
12. HF Lenz engineering does not provide comment to the use of a lift within the building on above grade floors. The availability of existing drawings is limited.
13. Fuel for generator operation is CCAC responsibility.
14. Rework and provide (two) 277V toggle switches within existing workboxes adjacent to panel EMB on 3rd floor.

End of Addendum 1

Sign addendum and return to the College with your response.

Company Name

Bidder's Signature