

COMMUNITY COLLEGE OF ALLEGHENY COUNTY  
PURCHASING DEPARTMENT  
800 ALLEGHENY AVENUE, PITTSBURGH, PA 15233

**ADDENDUM 2**  
**BID PROPOSAL NO. 1144**  
**PARTIAL WINDOW REPLACEMENT – BYERS HALL – ALLGHENY CAMPUS**  
**AUGUST 25, 2025**

The following additional information is hereby made a part of this bid:

\*\*\*\*\*

**Question and Answer:**

The glass calls for clear glass and I am assuming Low E coating for energy efficiency is not required?

**Response:**

Due to the historic status of this building, clear glass was selected to be in line with the glass that is currently on the building.

**End of Addendum 2**

\*\*\*\*\*

Sign addendum and return to the College with your response.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Bidder's Signature