

COMMUNITY COLLEGE OF ALLEGHENY COUNTY
PURCHASING DEPARTMENT
800 ALLEGHENY AVENUE, PITTSBURGH, PA 15233

ADDENDUM 3
BID PROPOSAL NO. 1149-2
REPLACE ROOF – BOYCE CAMPUS
ROOFING, GENERAL, HVAC, AND PLUMBING
JUNE 18, 2026

The following additional information is hereby made a part of this bid:

Questions and answers on asbestos:

According to the asbestos report provided and the roof drawing, roofs A and C contain asbestos tar paper. Please confirm if this applies to both the field of the roof and the flashings, as several samples taken from those areas did not contain asbestos.

For Roofs A & C the roof tar paper (roof cores) were asbestos. This includes the entire roof 'field'. There was no perimeter flashing identified. The caulking was negative.

Additionally, please note that not all roof areas were tested. Should we assume that these areas do not contain asbestos?"

Roofs A thru F were included in the inspection (see drawing in report). Asbestos was only identified on Roofs A & C. Roofs B, D, E and F were all negative.

End of Addendum 3

Sign addendum and return to the College with your response.

Company Name

Bidder's Signature