

COMMUNITY COLLEGE OF ALLEGHENY COUNTY
PURCHASING DEPARTMENT
800 ALLEGHENY AVENUE, PITTSBURGH, PA 15233

ADDENDUM 2
BID PROPOSAL NO. 1153
SECURITY CAMERA SYSTEM – BOYCE CAMPUS – NORTH LOT
OCTOBER 9, 2026

The following additional information is hereby made a part of this bid:

Various Questions and Answers:

Q1: Can we use equipment to dig the trench from pole #8C to the building since this trench will be ~ 48" deep instead of hand digging per the note on drawing E100?

A1: Underground utility information for this portion of the project is not available at this time - contractor shall obtain utility information from CCAC as practicable.

Q2: I am assuming that the interior 2" conduit will be deleted under Alternate #1 also. Is this correct?

A2: Yes - building interior work and 2" interior conduit is eliminated under deduct alternate #1.

Q3: What is the anticipated construction schedule duration and NTP date for this project? Due to the majority of this work occurring outside, we have to account for weather factors in our proposal (such as winter months, etc.).

A3: The target is to have work completed this year but depending on the total amount at which the bids come in, this work may need to be put off until next year with completion by June 30, 2027.

Q4: It was stated at the pre-bid that the Owner will trim the trees and bushes. I walked the new trenches from pole #4B to the existing handhole and to pole #4A. There are trees and roots that will need removed also. Is the Owner providing all clearing and grubbing for the new trenches?

A4: Contractor shall provide all root clearing / "grubbing" for trenches. CCAC will provide overhead tree trimming.

Q5: Is there a spoil site on the campus grounds or should we figure disposal of spoils off-site?

A5: Clean soil (and asphalt removed from CCAC driveway for trenching) removed from CCAC property may be disposed of in the wooded area west of the North Lot - not on the dirt road to the soccer field and not on planted or grass areas. Verify exact location w/ CCAC PM prior to beginning work.

End of Addendum 2

Sign addendum and return to the College with your response.

Company Name

Bidder's Signature